

C/M or P/M Reviewed:	<u>CONSTRUCTION JOB HAZARDS ANALYSIS</u> <i>Window Washing</i>	
Building & Room(s):	Contractor/Subcontractor Name:	Rev: 2015
Project:	Date:	
<p>Scope of Work: Please provide your scope of work to be performed (window washing while repelling over the roof edge). (and remove these directions).</p>		

Tasks being Performed	Potential Safety Risks/Hazards	Safety Controls / Mitigations
<p><u><i>This is a TEMPLATE</i></u></p> <p>Washing Exterior / Interior windows from ground level.</p> <p>Wash windows using a Tucker Pole & bucket with Squeegees</p> <p>Work to be performed from a elevated work surface (see attached ladder JHA) (see attached aerial/scissor lift JHA)</p> <p>Wash windows from boatswain's chair. <i>(SSSP is required)</i> <i>(Fall Protection Matrix Required)</i></p> <p>Chemicals being used: <i>(window cleaner)</i> <i>See Chemical JHA</i></p> <p><i>(and remove these directions).</i></p>	<p>Risks of exposure to a fall</p>	<p>Working from heights over 6' of an unprotected edge without the guardrail system in place , <i>fall protection is required.</i></p> <p><i>When Fall Protection is infeasible, A Fall Protection Plan will be "REQUIRED"</i></p> <p>A Fall Protection Matrix is <i>"REQUIRED"</i> when using FP equipment.</p> <p>Follow FP Matrix guidelines for equipment & system use.</p> <p>All workers shall remain 15' from an unprotected edge with the use of a Warning Line System.</p> <p><i>Follow the Site Specific Safety Plan</i></p>
	<p>Risk of storm water pollution</p>	<p>Follow SWPP Program as required.</p> <p>With storm drains that are below work area, ensure the drain is surrounded by waddles, lined with mess covers & tablets.</p>
	<p>Risk of slip, trips & falls</p>	<p>Area on, near or around the working surface is to be kept clear of any debris.</p> <p>Be aware of your surroundings at all times.</p> <p>Maintain proper footing and body positioning.</p>

Employee Signatures:	Date:

Employee Signatures:	Date:

Employee Signatures:	Date:

A signed copy of this JHA must be posted while the applicable subcontractor is working on-site and be available to any employee upon request.